




13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**



ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2016
Received: 08/16/2016
Sampled By: Brian Faist
Work Order: 6229013

**C
L
I
E
N
T**

Rivergrove Water
Attn: DJ Ezell
17661 Pilkington Road
Lake Oswego OR, 97035-5360
Phone: (503) 635-6041

Project: Pb + Cu
Project # : N/A
PWSID # : 4100461

Sampling Location: Rivergrove Water District

Lab Number

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6229013-01	Sample Name: 1. 5146 Dawn 97035 Sampled: 8/11/16 15:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.340	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-02	Sample Name: 2. 19050 Pilkington Rd 97035 Sampled: 8/15/16 6:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.320	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-03	Sample Name: 4. 5775 Childs Rd 97035 Sampled: 8/9/16 7:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-04	Sample Name: 6. 5312 Childs Rd 97035 Sampled: 8/9/16 7:00						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-05	Sample Name: 7. 5366 Red Leaf St. 97035 Sampled: 8/8/16 22:00						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	0.0047	0.0040	0.015	09/08/16 17:16
6229013-06	Sample Name: 8. 18926 Arowood Ave 97035 Sampled: 8/9/16 5:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	0.0049	0.0040	0.015	09/08/16 17:16



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2016
Received: 08/16/2016
Sampled By: Brian Faist
Work Order: 6229013

C **Rivergrove Water**
L Attn: DJ Ezell
I 17661 Pilkington Road
E Lake Oswego OR, 97035-5360
N Phone: (503) 635-6041
T

Project: Pb + Cu
Project # : N/A
PWSID # : 4100461

Sampling Location: Rivergrove Water District

Lab Number

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6229013-07	Sample Name: 9. 4903 Indian Cir. Ct. Sampled: 8/9/16 11:00						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-08	Sample Name: 10. 18926 Indian Springs Cir Sampled: 8/9/16 6:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.340	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-09	Sample Name: 12. 18951 Indian Spr. Rd. 97035 Sampled: 8/9/16 8:45						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-10	Sample Name: 15. 4039 Coho Ln 97034 Sampled: 8/9/16 7:00						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.343	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-11	Sample Name: 16. 4018 Coho Ln 97034 Sampled: 8/9/16 15:45						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.075	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	0.0050	0.0040	0.015	09/08/16 17:16
6229013-12	Sample Name: 18. 19166 Olson Ave 97034 Sampled: 8/9/16 6:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
†Copper	1055	SM3111B	mg/L	0.087	0.050	1.3	09/14/16 15:27
†Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2016
Received: 08/16/2016
Sampled By: Brian Faist
Work Order: 6229013

C **Rivergrove Water**
L Attn: DJ Ezell
I 17661 Pilkington Road
E Lake Oswego OR, 97035-5360
N Phone: (503) 635-6041
T

Project: Pb + Cu
Project # : N/A
PWSID # : 4100461

Sampling Location: Rivergrove Water District

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6229013-13	Sample Name: 19. 19468 35th Ct 97034 Sampled: 8/9/16 7:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.803	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-14	Sample Name: 20. 19220 Red Wing Ct. 97035 Sampled: 8/9/16 6:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	ND	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-15	Sample Name: 23. 4023 Trout Way 97034 Sampled: 8/9/16 8:30						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.402	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-16	Sample Name: 24. 4004 Bass Ln 97034 Sampled: 8/9/16 7:10						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.160	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-17	Sample Name: 26. 4075 Coho Ln 97034 Sampled: 8/9/16 6:45						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.231	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-18	Sample Name: 27. 3852 Bass Ln Sampled: 8/9/16 5:20						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.357	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2016
Received: 08/16/2016
Sampled By: Brian Faist
Work Order: 6229013

C **Rivergrove Water**
L Attn: DJ Ezell
I 17661 Pilkington Road
E Lake Oswego OR, 97035-5360
N Phone: (503) 635-6041
T


Project: Pb + Cu
Project # : N/A
PWSID # : 4100461

Sampling Location: Rivergrove Water District

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6229013-19	Sample Name: 29. 3778 Rivers Edge Dr. Sampled: 8/9/16 7:18						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.448	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16
6229013-20	Sample Name: 30. 18938 Longfellow 97035 Sampled: 8/9/16 5:45						Matrix: Drinking Water
<i>Metals (Total)</i>							
+Copper	1055	SM3111B	mg/L	0.290	0.050	1.3	09/14/16 15:27
+Lead	1030	EPA 200.9	mg/L	ND	0.0040	0.015	09/08/16 17:16

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director